

North Penn School District

Liquid Propane Gas (LPG) Storage and Maintenance 2019

ADDENDUM #2

ISSUED April 12, 2019

The following sections of the general conditions have been changed.

Due Date

The bid due date has been extended to April 30, 2019, at 2:30 PM, at the Educational Service Center, 401 E. Hancock St., Lansdale, PA.

Construction Timeframe

The district has a preferred completion date of August 1, 2019 and a required completion date of October 1, 2019. In the event that the bidder cannot complete the construction work by August 1, 2019 the bidder must provide a temporary fueling solution until the completion of installation. The pricing of propane on the temporary fueling station must be equal to the price bid for fuel during the period of August 1, 2019 through June 30, 2021.

Construction – Propane Autogas Dispenser Specifications

The district requests the bid to include two (2) dispensers with two (2) fueling hoses and (2) pumps per dispenser, to provide the district the ability to fill four buses simultaneously.

Construction – Installation Foundation

The district request that the bidder include the installation of the concrete pad and the required crash safety protection equipment (required bollards) surrounding the tank location. Fencing will remain the responsibility of the district.

- Excavate 24" of soil and disposal of same.
- Compact the subgrade
- Fill with 16" of crushed stone and compact.
- Form and pour 8" thick concrete slab (3,500 psi certified concrete mix) the estimated pad would need to be 10' x 50'
- Supply and install (32) 7-foot long steel bollards. 4 feet above grade, 3 feet below grade in concrete

Construction – General

All necessary sealed drawings will be the responsibility of the bidder.

Site Location


Attached is a satellite image of the requested installation site.

Additional Contacts

Scott Kennedy – Site Visit and Electrical Access
NPSD Director of Facilities and Operations
215-853-1140
kennedsd@npenn.org

Nick Kraynak - Site Visit
NPSD Coordinator of Transportation
215-853-1120
kraynana@npenn.org

Towamencin Township
Jennifer Guckin – Permits
Director of Community Planning/Code Enforcement Officer
215-368-7602
jguckin@towamencin.org



Imagery ©2019 Google, Map data ©2019 Google 50 ft

Approximate
Tank Location